

NBN-00383-02.04-01/27/81

JENNINGS LABORATORIES, INC.

ANALYTICAL AND CONSULTING CHEMISTS

1118 CYPRESS AVENUE • P. O. BOX 851 • VIRGINIA BEACH, VA. 23451 • PHONE (804) 425-1498

VA (EPA) CERTIFIED LABORATORY for
Drinking Water Analysis - Microbiological,
Inorganic and Organic

ASBESTOS ANALYSIS - NIOSH 582

Official Referee Chemists for:
AMERICAN OIL CHEMISTS SOCIETY
NATIONAL SOYBEAN
PROCESSORS ASSOCIATION

Laboratory Approved by VA. STATE WATER
CONTROL BOARD for Analysis of
Effluents for NPDES PERMITS
CERTIFIED OFFICIAL U.S.D.A. LABORATORY
FOR MEAT ANALYSIS

CERTIFICATE OF ANALYSIS

TO: Mr. Dave Goodwin
Building N-23 Atlantic Division
Naval Facilities Engineering Command
Norfolk, Virginia 23511

DATE: November 27, 1981

SAMPLE OF TRANSFORMER OIL SAMPLES (5)

MARKED Camp Allen Salvage Building #231

Picked up by JENNINGS LABORATORIES, INC. 11/24/81

OFFICIAL SAMPLE BY: _____

SAMPLE AS MARKED

PCB CONTENT

Lab #559 - Sample #1 RTE CORP. Wadkesha, Wisc.
Ser. #761068797 Cap. 12 gls-15 KVA Cap & Type:
#264T5H

None Detected (<0.01 ppm)

Lab #560 - Sample #2 GE (incomplete plate)
Ser. #4925008 Cap. 60 gls Type 9FH243 on pallet:
#8852

None Detected (<0.01 ppm)

Lab #561 - Sample #3 RTE CORP Wadkesha, Wisc.
Ser. #761068787 Cap. 12 gls-15 KVA Cap & Type:
#264T5H

None Detected (<0.01 ppm)

Lab #562 - Sample #4 RTE CORP. Wadkesha Wisc.
Ser. #761068795 Cap. 12 gls-15 KVA Cap & Type:
#264T5H


None Detected (<0.01 ppm)

Lab #563 - Sample #5 RTE CORP. Wadkesha, Wisc.
Ser. #761068794 Cap. 12 gls-15 KVA Cap & Type:
#264T5H

None Detected (<0.01 ppm)

Respectfully submitted,
JENNINGS LABORATORIES, INC.

Laboratory
Analysis No. listed above


CHEMIST